



NOTES:

1. REFER TO GI-1 NOTES FOR GUIDELINES AND CHECKLIST.
2. CHECK DAMS SHALL BE SPACED TO PROVIDE PONDING PER SITE SPECIFIC DESIGN (SEE DETAIL GI-7).
3. LAY OUT DRAINAGE NOTCHES AS APPLICABLE TO PREVENT PONDING BEHIND BIORETENTION AREA WALL WITH 5' MAXIMUM SPACING BETWEEN NOTCHES.
4. PROVIDE ONE UNDERDRAIN CLEANOUT PER BIORETENTION AREA (MIN). CLEANOUT REQUIRED AT UPSTREAM END AND PIPE ANGLE POINTS EXCEEDING 45 DEGREES. LONGITUDINAL SLOPE OF PIPE SHALL BE 0.5% (MIN).



BIORETENTION AREA: PLAN VIEW WITH STREET PARKING

**GREEN INFRASTRUCTURE
TYPICAL DETAILS**
CITY OF DUBLIN PUBLIC WORKS

SCALE: NOT TO SCALE

DATE: MAY 11, 2018

DRAWN BY: K. K.

CHECKED BY: A. R.

APPROVED:

PUBLIC WORKS DIRECTOR

GI-2A